

Type Approval Certificate

This is to certify that the undernoted product(s) has/have been tested with satisfactory results in accordance with the relevant requirements of the Lloyd's Register Type Approval System.

This certificate is issued to:

PRODUCER Parker Hannifin Manufacturing Limited

PLACE OF Dukesway

PRODUCTION Team Valley Trading Estate, Gateshead

Tyne & Wear NE11 0PZ United Kingdom

DESCRIPTION CDASHL CLEAN DRY AIR SYSTEM

TYPE CDASHL 050, CDASHL 055, CDASHL 060, CDASHL 065,

CDASHL 070, CDASHL 075, CDASHL 080, CDASHL 085

APPLICATION Compressed Air Treatment

STANDARDS ISO 7183: 2007 Compressed-air dryers – Specifications and testing

ISO8573-1:2010 Contaminant and purity classes ISO8573-2:2007 Test Methods for oil aerosol content

ISO8573-3:1999 Test Methods for measurement of humidity ISO8573-4:2001 Test Methods for solid particle content

ISO12500-1:2007 Filters for compressed air – Test methods – Oil Aerosols

RATINGS Dryer sized for -20°C PDP ISO8573-1:2010 Class 2:3:2

Dryer sized for -40°C PDP ISO8573-1:2010 Class 2:2:2 Dryer sized for -70°C PDP ISO8573-1:2010 Class 2:1:2

"This Certificate is not valid for equipment, the design, ratings or operating parameters of which have been varied from the specimen tested. The manufacturer should notify Lloyd's Register EMEA of any modification or changes to the equipment in order to obtain a valid certificate."

When tested in accordance with the requirements of ISO 7183:2007 and challenged with the inlet conditions of 7bar.g, 35°C, 100% humidity, 25°C ambient temperature and 100% rated flow (as set out in

Certificate No. 17/ 00002

Issue Date 13th January 2017

Expiry Date 12th January 2022

Sheet 1 of 2

D. Hardacre Lead Specialist – Design Appraisal LR Inspection Services

Lloyd's Register EMEA 71 Fenchurch Street, London EC3M 4BS

> Lloyd's Register EMEA Is a subsidiary of Lloyd's Register Group

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as the 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.



the above standard in Table 2 Option A1), the test dryers achieved the following outlet pressure dew points (PDP):

- When flowed to achieve a pressure dew point of -20°C, the test dryers achieved a consistent outlet pressure dew point ≤ -20°C, equating to ISO8573-1:2010 Class 3 for water.
- When flowed to achieve a pressure dew point of -40°C, the test dryers achieved a consistent outlet pressure dew point ≤ -40°C, equating to ISO8573-1:2010 Class 2 for water.
- When flowed to achieve a pressure dew point of -70°C, the test dryers achieved a consistent outlet pressure dew point ≤ -70°C, equating to ISO8573-1:2010 Class 1 for water.

The CDASHL dryer range is supplied as a package with Grade AO and AA coalescing filters and Grade AO dry particulate filters. The combined ISO8573-1 classifications are stated in the Ratings section above. The class designation is ISO8573-1:2010 [A:B:C], where:

A is the purity class for particles;

B is the purity class for humidity and liquid water;

C is the purity class for oil.

The filter models described above have been tested at ISO reference conditions, in accordance with the requirements of ISO12500-1:2007. When challenged with up to 40mg/ m³ of oil aerosol only, the measured residual oil content downstream of the test filters averaged <0.01mg/ m³, resulting in downstream air purity equal to Class 2 for oil as defined by ISO8573-1:2010.

The filter models described above have been tested in accordance with the requirements of ISO8573-4:2001. The outlet filter removes particles down to 1 micron resulting in downstream air purity equal to Class 2 for solid particulate as defined by ISO8573-1:2010.

Power consumption (peak & average) & purge air volume were also tested and recorded in accordance with ISO7183:2007.

Details of the equipment, methodology and results are contained within the Technical Documentation File COV1613827/ TDF/ 1.

The Design Appraisal Document No. COV1613827 O-33199/DH and its supplementary Type Approval Terms and Conditions form part of this Certificate.

Certificate No. 17/ 00002

Issue Date 13th January 2017

Expiry Date 12th January 2022

Sheet 2 of 2

D. Hardacre Lead Specialist – Design Appraisal LR Inspection Services

Lloyd's Register EMEA 71 Fenchurch Street, London EC3M 4BS

Lloyd's Register EMEA Is a subsidiary of Lloyd's Register Group

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as the 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.